

Document Review Comment Sheet

PEB Ref. No : TB2-PEB-SDC-M1A-TVI-01674

No.	Document No.	Rev	Title	Purpose	Review Status	
					In	Out
1	TB2-SDC.VP124-00HSJ-M-M1A-PFD-0001 to -0020	0	SCR Material Balances	FF		IB
No.	TB2PEB's Comments	Item status	Contractor's Response			
I	GENERAL COMMENTS					
	Document shall be submitted "For construction only after having approval owner's approval status as "A" or "B".		Confirm.			
II	DETAIL COMMENTS					
1	TB2-SDC.VP124-00HSJ-M-M1A-PFD-0010					
1.1	Unit Load - "All HP Heater Off" is not a required unit condition. Delete. Replace with Valves Wide Open "VWO" condition. PEB Response - Comment not correct.	Close	Please clarify whether just change name of load condition from "All HP Heater Off" to "VWO" or change the unit load condition from "All HP Heater Off" condition to "VWO" condition. If the VWO load condition is different from "All HP Heater Off" load condition, we are not receipt flue gas data for "VWO" load condition.			

* Legend

Contractor Purpose:

AP - For Approval
RE - For Reference
FC - For Construction
AB - As Built
INFO - For Information

Approval Status:

A - Approved
B - Approved with Comments
C - Returned for Correction
D - Rejected
I - Accepted for Reference / IB - Accepted for Reference with Comments / R - Returned for Correction